

# T E S T C E R T I F I C A T E

ST-12-01-05-02

**Product:** Laminate floor covering "**ROOMS - penthouse**"  
Dimensions: 1845 mm x 188 mm x 12 mm

**Producer:** KRONOTEX GmbH & Co. KG  
Wittstocker Chaussee 1  
16909 Heiligengrabe

**Order/**

**Test method:** Testing of the properties according to EN 13329

**Test report:** 279404\_A1/1

**Test results:**

- The general requirements according to table 1 and 3 are fulfilled.
- The classification requirements of the following levels of use are fulfilled:


Resistance against abrasion:	classes 21 - 23, 31 - 34
Resistance against impact:	classes 21 - 23, 31 - 33
Resistance against staining:	classes 21 - 23, 31 - 33
Resistance against cigarette burn:	classes 21 - 23, 31 - 33
Resistance against movement of a furniture leg:	classes 21 - 23, 31 - 33
Resistance against soft chair rolls:	classes 21 - 23, 31 - 33
Thickness swelling:	classes 21 - 23, 31 - 33

The Product "**ROOMS - penthouse**" fulfils the general requirements according to table 1 and 3 and the classification requirements for the level of use 21 - 23 and 31 - 33 according to EN 13329.

Dresden, 05 January 2012



Head of laboratory



Engineer in charge